

SE-108291M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DALI bus powered motion sensor

Name and address of the applicant

TE Connectivity Corporation 2901 Fulling Mill Road, Middletown, PA 17057,

United States of America

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

24V, 1W, 0.05A, IP66, IK08

Trademark / Brand (if any)

Model / Type Ref.

= TE

Customer's Testing Facility (CTF) Stage used

2388426-*, 2444029-*

Additional information (if necessary may also be reported on page 2)

□ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015+A1 IEC 61347-2-11:2001+A

As shown in the Test Report Ref. No. which forms part of this Certificate

105040480CHI-001 105040480CHI-001M1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB Torshamnsgatan 43 Box 1103 SE-164 22 Kista, Sweden

intertek

Date: 18 August, 2023

Signature: Quan Li Quan Li

1/2 AMP



SE-108291M1

Additional information The * could indicate another variable that we would provide to a customer (different light turn on level programmed into the device for example) but would not alter materials, PCB layout, PCB components, etc. This certificate replaces the CB certificate SE-108291 dated 10 June 2022 due to added model "2444029-*". anan Li Date: 18 August, 2023 Signature:

2/2 AMP