



Tyco Electronics UK Limited
Energy Division
Freebournes Road, Witham,
Essex, CM8 3AH, UK

Tel.: +44 1376 509 509
Fax: +44 1376 509 511
<http://energy.tycoelectronics.com>



Declaration of Conformity

We,

Tyco Electronics (Crompton Instruments) Ltd
Witham, United Kingdom.

declare under our sole responsibility that the product(s)

250 series Protector Trip Relays

Models:

252 – P* **

253 – P* **

256 – P* **

Where * = A, V, H, S, L, D, M, R, C, B, or T

Where ** = U, O, D, P, V, K, A, B, M, Z, H, X, S, C, J, R, F, G, Q, T, L, E, or 3,
followed by additional characters

comply with the essential requirements and provisions of EU Directive(s)

2014/35/EU	Relating to Low voltage equipment (LVD)
2014/30/EU	Relating to Electro-magnetic compatibility (EMC)
2011/65/EU	Relating to the restriction of hazardous substances (RoHS)

are in conformity with the following harmonized standard(s) or normative document(s) and CE marked accordingly

EN 61010-1:2010	Safety requirements of electrical equipment for measurement, control and laboratory use – part 1: General requirements
EN 61010-2-030:2010	Safety requirements of electrical equipment for measurement, control and laboratory use – part 2-030: Particular requirements for testing and measuring circuits
EN 61326-1:2013	Electrical equipment for measurement, control and laboratory use – EMC requirements
EN 50581:2012	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances


N Johnson
EMEA Product Manager


C Brown
Quality Manager

Year of CE marking: 1992

Registered Office: Faraday Road, Dorcan
Swindon, Wiltshire, SN3 5HH, UK
Registered No. 550926
VAT No. GB 681 471 425



Certificate No. FM21540