

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED driver with integral LED holder

Name and address of the applicant

TE Connectivity Nederland B.V.

Rietveldenweg 32,

5222 AR 's-Hertogenbosch

The Netherlands

Name and address of the manufacturer

TE Connectivity Nederland B.V.

Rietveldenweg 32,

5222 AR 's-Hertogenbosch

The Netherlands

Name and address of the factory

Additional information on page 2

Note: When more than one factory, please report on page 2

Tyco Electronics NZL 14 Mary Muller Drive

Hillsborough Christchurch 8022 New Zealand

Ratings and principal characteristics

U input 48 Vdc, U output: 36 Vdc, tc = +110 °C

I out 350 mA ... 1050 mA (see general product information)

Trademark (if any)

TE

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LUMAWISE Drive LED Holder Type Z50 DALI / X-2316511-Y (see general product information)

Additional information (if necessary may also be reported on page 2)

Additional information on page 2

Product key:

X-2316511-Y

Where:

X= output current (0, 1, 2 or 3) 0 (or no prefix)= 350 mA

1= 500 mA 2= 700 mA 3= 1050 mA

Y= CoB size (24*24, 20*24, 19*19, 16*19)

1= CoB size 24*24 2= CoB size 20*24 3= CoB size 19*19 4= CoB size 16*19

A sample of the product was tested and found to be in conformity with

IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands





IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

As shown in the Test Report Ref. No. which forms part of this Certificate

2224069.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051, NL-6825 MJ Arnhem, Netherlands

Date: 2018-05-15



Signature: H.L. Sche

page 2 of 2