SAFETY ORGANIZATIONS

THIS FILTER IS A VERSION OF THE ISSRBB-X, WHICH HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 (REF. 15SRB8-X)
CSA CERTIFIED: CSA 22.2, ND. 8 (REF. 15SRB8-X) VDE APPROVED: EN 60939-2 (REF. 15SRBB-X)

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 15 AMP, 120/250 VAC 10 AMP/40°C, 250 VAC

50-60Hz I THE EREDIENCY:

MAXIMUM LEAKAGE CURRENT,

70 µ A @120V 60Hz EACH LINE TO GROUND: 130 µ A @ 250V 50Hz

DPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, I_{C} .

IN AN AMBIENT, T₀ , HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, I $_{0}$, IS AS FOLLOWS: I $_{-}$ = I $_{-}$ $_{$ 100 - T₀

 $I_0 = I_r -$ 60

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES I, FOR 8 SECONDS

CUSTOMER DRAWING CATALOG # 15SRBY8-X <u>ECN # APPRVD. DATE</u> 030CT08 ELC

TEST SPECIFICATIONS:

INDUCTANCE: 0 mH NDMINAL

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

1000 pF ±20% 0.0 pF LINE TO GROUND: LINE TO LINE: DISCHARGE RESISTOR NUNE

L/G AND L/L I.R.

NO DISCHARGE RESISTOR: 6000M ← (MIN.) @ 100VDC,

20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC FOR 1 MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

