



# Certificate of Compliance

**Certificate:** 1088108 (LR 7189-207)

**Master Contract:** 164196

**Project:** 2708701

**Date Issued:** July 4, 2014

**Issued to:** Tyco Electronics Corporation

2901 Fulling Mill Rd  
Mail Stop 140-08  
Middletown, PA 17057-3163  
USA  
Attention: Mr. Kurt Farr

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Mike W. Gryschuk*

Issued by: Mike W. Gryschuk, C.E.T.

## PRODUCTS

**CLASS 6233 01** - RECEPTACLES - Attachment Plug Type and Plugs

**CLASS 6233 81** - RECEPTACLES - Attachment Plug Type and Plugs - Certified to US Standards

Special use "AMPLIMITE" connectors, plugs and receptacles, rated 7.5A Max, 125V.

Special use "AMPLIMITE .050" connectors, plugs and receptacles, rated 1A, 30V.

## APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 182.3-M1987, 1st Ed - Special use attachment plugs, receptacles, and connectors

UL Std. No. 1977, 2nd Ed - Component Connectors for Use in Data, Signal, Control and Power Applications

# Descriptive Report and Test Results

MASTER CONTRACT: 164196

REPORT: 1088108

PROJECT: 2708701

**Edition 1:** March 19, 1991; Application No LR 7189-207 - Toronto  
Issued by John Ferguson; Reviewed by D. Hay, P. Eng.

**Edition 14:** July 24, 2000; Project: 1088108 - Toronto  
Issued by Bruce Wright, Technologist

Report Reissued

**Edition 22:** July 9, 2012; Project 2530835 - Toronto  
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued

**Edition 23:** July 4, 2014; Project 2708701 - Toronto  
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued

Contents: Certificate of Compliance - Pages 1 to 1  
Supplement to Certificate of Compliance - Pages 1 to 1  
Description and Tests - Pages 1 to 8  
Figures - Figs 1 to 4 (in Documentum)  
Test Records Attached - Part A (Pages - 1 to 12); Part B (Pages - 1 to 3)  
Part C (Pages - 1 to 1); Part D (Pages - 1 to 1)  
Part E (Pages - 1 to 4)

## PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

CLASS 6233 81 - RECEPTACLES - Attachment Plug Type and Plugs - CERTIFIED TO U.S. STANDARDS

Special use "AMPLIMITE" connectors, plugs and receptacles, rated 7.5A Max, 125V.

Special use "AMPLIMITE .050" connectors, plugs and receptacles, rated 1A, 30V.

## APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 182.3-M1987, 1st Ed - Special use attachment plugs, receptacles, and connectors

UL Std. No. 1977, 2nd Ed - Component Connectors for Use in Data, Signal, Control and Power Applications

This report shall not be reproduced, except in full, without the approval of CSA Group.

178 Rexdale Boulevard, Toronto, ON, Canada M9W 1R3  
Telephone: 416.747.4000 1.800.463.6727 Fax: 416.747.4149 www.csagroup.org

## MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The Submitter's name ("Tyco" or "AMP")/tradenname/trademark/file ("164196" or "LR 7189") and the CSA Mark are permanently marked on each device. The letters "C US" may appear below the CSA Mark (if desired).

The Cat No may appear on each device.

The Submitter's identification, the CSA Mark, the letters "C US" may appear below the CSA Mark (if desired), the electrical rating, the Series designation (ie "AMPLIMITE"), the Cat No (where applicable) and the following (or equivalent) wording: "CAUTION: NOT FOR INTERRUPTING CURRENT" and "ATTENTION: NE PAS UTILISER POUR COUPER LE COURANT" appear on or in the smallest packaging unit.

## ALTERATIONS

See "Markings" above.

## FACTORY TESTS

None.

## SPECIAL INSTRUCTIONS FOR FIELD SERVICES

None.

## COMPONENT SPECIAL PICKUP

None.

## DESCRIPTION

### Conditions of Acceptability:

1. Supplied only to manufacturers, as components, for assembly of Certified electrical equipment, where the acceptability of the suitability of the combination in the end use is determined by CSA International.
2. Not for interrupting current.
3. Suffixes may be added.
4. This part numberless report does not limit Certification to any specific Cat No found in this report.