



Certificate of Compliance

Certificate: 1501843

Master Contract: 164196

Project: 80024254

Date Issued: 2019-11-19

Issued To: TE Connectivity Corporation
2901 Fulling Mill Road
Middletown, Pennsylvania, 17057-3163
United States

Attention: Steve Bolash

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Michael Chung
Issued by: Michael Chung

PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

CLASS 6233 81 - RECEPTACLES - Attachment Plug Type and Plugs - CERTIFIED TO U.S. STANDARDS

Special-use "METRIMATE" male and female connectors Series 207XXX, 208XXX, 211XXX, 212XXX, 213XXX, rated 24A (1-pole), 11A (2 to 18-poles), 9A (19 to 36-poles), 6A (37 to 62-poles), 600V.

Special-use "METRIMATE" female connectors Series 1604520, rated 13A (1-pole, No 14 AWG), 3A (31-poles, No 14 AWG), 2.5A (62-poles, No 14 AWG), 12A (1-pole, No 16 AWG), 2A (31-poles, No 16 AWG), 1.5A (62-poles, No 16 AWG), 12A (1-pole, No 18 AWG), 1.5A (31-poles, No 18 AWG), 1.0A (62-poles, No 18 AWG), 8A (1-pole, No 20 AWG), 1A (31-poles, No 20 AWG), 1.0A (62-poles, No 20 AWG), 7A (1-pole, No 22 AWG), 0.75A (31-poles, No 22 AWG), 0.75A (62-poles, No 22 AWG), 6A (1-pole, No 24 AWG), 0.75A (31-poles, No 24 AWG), 0.75A (62-poles, No 24 AWG), 600V.



Certificate: 1501843
Project: 80024254

Master Contract: 164196
Date Issued: 2019-11-19

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No 182.3-16, 2nd Ed - Special Use Attachment Plugs, Receptacles, and Connectors
UL Std. No 1977, 3rd Ed - Component Connectors for Use in Data, Signal, Control and Power Applications